

Connecting the humidifier B 600 to a WLAN

Switch on the humidifier B 600, after a short time a new network should be visible.

To do this, search the network environment on the PC or search for "Brune WLAN" under Network & Internet settings (mobile device) and connect to it:



The IP address 192.168.4.1 should now be displayed on the device.





Using a web browser, enter the IP address 192.168.4.1 as shown in the device and open the start page of the network setup.

 C WLAN-Modul ← C ▲ Nicht sicher 192.168.4 	4.1
WLAN-Modul	Settings
MAC: 2C:BE:97:01:1F:CB	

Click on "Settings" to open a new menu for the WLAN configuration.



	N-Modul × +			D B WLA	AN-Modul × +	
\leftarrow C	A Nicht sicher 192.168.4.1/	'settings.html		← C	A Nicht sicher 192.168.4.1	/settings.html
Settings Back		_	Setting	IS	Back	
WLAN Configuration				WLAN Co	nfiguration	
Modus	Config 🗸			Modus	Client ~	
Autojoin			ŗ	Autojoin		
Kanal	1 ~			Kanal	1 🗸	
Stationen	1 🕶			Stationen	1 🕶	
SSID				SSID		
PWD				PWD		
AP-SSID	AP-SSID			AP-SSID	AP-SSID	
AP-PWD	password			AP-PWD	password	
		Apply				Apply
Software				Software		
App:	WLANModul			App:	WLANModul	
Ver:	0.10.1			Ver:	0.10.1	
Compiled:	Jan 18 2023 16:33:20			Compiled:	Jan 18 2023 16:33:20	
IDF Ver:	v4.4.2-dirty			IDF Ver:	v4.4.2-dirty	
		Update				Update

- 1.) The mode must be changed from "Config" to "Client".
- 2.) Enter the name of your existing WLAN network in the SSID field.
- 3.) Enter the corresponding password for your WLAN network in the PWD field.

Finally, transfer all entries to the device with "Apply".

The device now connects to the existing WLAN and receives a new IP address. It can now be controlled with the Brune Control APP (available for iOS and Android) or in the remote portal.



LUFTBEFEUCHTER	12:22	Di, 31.01.2023
	VERBUNDEN	
IP-AC Mi GR	DRESSE: 192. 168. 111. 11; AC: 2C:BE:97:01: 1F:CB ITEWAY: 192. 168. 111. 1 B600	2
	EINSTELLUNGEN	
«	NETZWERK	

Newly obtained IP address from your network; process thus successfully completed.

The humidifier B 600 is now ready for use.

The humidifier B 600 can now be controlled with the Brune Control app (available free of charge for Android and iOS).





Activate Brune WLAN / reset network settings

Press and hold the Settings button for 10 seconds. In the Network field, a counter counts down to 0. The Brune WLAN is then activated and the network settings are reset.

ATTENTION!

Once the countdown is complete, all settings of the WLAN/WiFi module are deleted.

To enable operation of the device via the remote portal, you must log in at <u>https://brune.remoteportal.de</u>.

To do this, enter the enclosed MAC address (see enclosed sticker) and the password below in the login window.







	Anmelden	
Benu	tzername oder MAC-Adr	esse:
	2C:BE:97:01:AF:C0	
	Passwort:	
	automatische Anmeldung	,
	Anmelden	

The start page of the remote portal opens and a configuration can be made.

Arlage "8600 UV-Variante" X +		-	0
← C (△ https://brune.remoteportal.de/index.php?pto]area]=-controller	A® Sõ		
		-	
- // / www.summer.com.arg	Li Li	etzter Kontakt zur Anlage: 31.01.2023	12:37
		B600 UV-Variante B500 Standard	00
		_	0

After registering, you can use the remote portal free of charge for 30 days via a trial account.